

STATIONARY CONTAINER SYSTEM COMPLIANCE CERTIFICATE

Issued pursuant to Regulation 6.23 of the Health and Safety at Work (Hazardous Substances) Regulations 2017.

Issued To: Cardrona Alpine Resort Ltd t/a Treble Cone Ski Field

Company Number:

Customer Contact Details: Mike Booth Cardrona Alpine Resort Ltd PO Box 206 Wanaka 027-3764382 Certificate No: 000377-37097

GPS Co-ordinates: -44.633241 Lat 168.896088 Long

Site Location: Treble Cone Ski Field (Diesel Tank) Mt Aspiring Road Wanaka

03-4437443

Issued in accordance with regulations 6.23 and 17.91 of the Health and Safety at Work (Hazardous Substances) Regulations 2017. This certificate certifies that the requirements prescribed in regulation 17.91 for a stationary container system compliance certificate have been met

Stationary Container Details:

Belowground Flammable Liquid Single Skinned Steel Design Std: HSNOCOP 13-2 Manufacturer: Unknown Tank Ser No: FWS085 Date of Manuf: 1996 Max Fill Capacity: 32,000 litres

Substance:Class 3.1DFlammable Liquids: Diesel

Information for the PCBU:

Equipment Details:

Tank Connected to 2 x Generator Sets:

- 1. F.G Wilson, Model P900E1, Ser No
 - FGWRPES3EDPS01785.
- 2. F.G Wilson, Model P715E, Ser No FGWPES03CUoA00746.

Maximum Quantity: 32,000 litres

This certificate is issued by Compliance & Certification Management Ltd being an individual compliance certifier authorised by WorkSafe New Zealand under regulation 6.8 of the Health and Safety at Work (Hazardous Substances) Regulations 2017, in accordance with regulation 6.8(2)(a) to (d) of those regulations.

This certificate becomes invalid if the above Stationary Container System is repaired, altered, relocated or there is a change of service in respect of the contents of the container.

Peter Menzies:

Compliance Certifier Registration 000377

Issue Date: 31st May, 2020

Commencement Date: 31st May, 2020

Expiry Date: 31st May, 2021